



**OFFICE OF THE DEPUTY FIRE OFFICER
BALASORE CIRCLE BALASORE**

FORM-V

FIRE SAFETY CERTIFICATE

(See rule-13(3) of the Odisha Fire Prevention and Fire Safety Rules, 2017)

File No-41/2019 /BLS CLE

Certificate No-30 /BLS CLE

Dt-12.09.2020

This certificate is valid up to **11.09.2022**


(Apply for renewal at least three months before expiry)

Certified that G+1 Floors Durga Prasad Saraf Vidyapeeth over plot No. 934 and other, Khata No. 198 and others, Village-D.P.Nagar, Po-Randia, Dist. Bhadrak, consisting of single Block was inspected by officers of Odisha Fire Service team on 23.08.2019 and re-inspected on 08.09.2020 in presence of the Principal cum Secretary, Durga Prasad Saraf Vidyapeeth, D.P.Nagar, Po-Randia, Dist. Bhadrak and it has been found to comply with the fire prevention and safety requirements in accordance with the Odisha Fire Prevention and Fire Safety (Amendment) Rules, 2019. Hence, its various floors are fit from fire safety point of view for occupancy or usage as noted hereunder against each, subject to compliance to the conditions as prescribed herein below:

Ground Floor	-- Usage--	Class room, Activities room, Computer lab, Science lab, Math lab, PET room, Music dance, Account Officer, A.O, Servicer room, Rest room, Staff room & Principal room
1 st Floor	-- Usage--	Library

CONDITIONS:-

1. Fire Prevention and safety measures and appliances, availability of water supplies and means of access thereto etc provided in the building or premises, should be maintained by the occupier (S) in best repairs and efficient working condition at all times for use by the occupants or the members of the Fire Service or both in the event of outbreak of fire.
2. The setbacks, driveways, entrance gates, exits, staircases, corridors and escape ways should not be changed, obstructed or modified in any way.
3. The occupier (S) shall train all staff and occupants periodically to make them well conversant in use and operation of fire prevention and safety measures.
4. Fire drills/rehearsals should be organized at least once in six months by involving local Fire Station.
5. Photocopies of this certificate should be framed and displayed at all conspicuous places in all lobbies/corridors in all tower/blocks of building/premises.


 12/9/2020

(Ramesh Chandra Sethy)
Deputy Fire Officer
Balasore Circle, Balasore

**Deputy Fire Officer
Balasore Circle, Balasore**